



Fall Protection Anchor - Recall

3M Fall Protection (formerly Capital Safety) Issues Stop Use/Recall

3M Fall Protection has received field reports of broken end-posts. These are part of the Free Standing Counterweight Anchor Systems that are using their Evolution LEAP post. LEAP post meaning Lead Energy Absorbing Posts. The Free Standing Counterweight Anchor System is designed as a portable means to anchor a personal fall arrest system for a person working on flat roofs or structures. These LEAP posts are also used in roof-mounted horizontal lifeline systems.

The manufacture states there have not been any fall related injuries reported as of their May 17, 2017 released recall notice.

These posts are on recall and will be replaced by the manufacture free of cost to end users. The P/N's affected include 7226000, 7240313, 7255000, 7255002 & 7255003.

The 3M Fall Protection notice with full instructions for end user is available at the following link:

<http://api.capitalsafety.com/api/assets/download/1/52626630>

SafeALERT



ORCIG 2017 SafeAlert Series

This material is intended to be a broad overview of the subject matter and is provided for informational purposes only. Old Republic Contractors Insurance Group, Inc. does not endorse or recommend any products or services nor does it make any representation or warranty regarding the accuracy or completeness of the information. Old Republic Contractors Insurance Group, Inc. shall have no liability or responsibility to any person or entity with respect to any loss, action or inaction alleged to be caused directly or indirectly as a result of the information contained herein.

